

**Subject: Clarification No. 1 of Construction of Liquid Nitrogen Plant**

**Publication Reference: BAM/ADMP/LNP/SUP/VC**

**Publication Date: 22<sup>nd</sup> December, 2015**

Procurement Title: Supply, Delivery, Installation and Commissioning of a Liquid Nitrogen Plant

Deadline for submission of tenders: 1:00pm local time on January 25, 2016

**Clarification requested by a contractor and answer is shown below.**

### **QUESTION 1**

We are seeking additional information on the technical specifications for the liquid nitrogen plant tender, reference code (BAM/ADMP/LNP/SUP/VC). The **purity** and **flow rate** were not specified in the technical specifications, this information is necessary for us to complete the tender document.

### **ANSWER 1**

The purity is 98.5-99% purity and the flow rate is 5 Liter per day.