CT SCAN
KITCHENETTE #2
KITCHENETTE #1
PLUMBING/ELECTRICAL AIR CONDITIONING REPAIR
BIOMEDICAL EQUIPMENT REPAIR
WASH RM.
WASH RM.
STORAGE
STAFF RM.
MEDICAL RECORDS STORE AND ADMIN OFFICE SPACE
ADMINISTRATION RECEPTION
SENIOR ENGINEER
WHEEL ITEMS REPAIR
WAITING
STORAGE
DN.
UP
RAMP UP
RAMP DN.
LECTURE HALL
MEN
WOMEN
PROPOSED STAFF LOUNGE
PROPOSED PHYSIOTHERAPY DEPARTMENT
STORAGE
PROPOSED FOOD STORAGE
PROPOSED CATERING SUPERVISOR
STORAGE
PROPOSED FOOD STORAGE #1
RELOCATED PANEL
PREPARATION
KITCHEN
GAS CYLINDER STORAGE
KITCHEN EXHAUST FAN ISOLATOR AT ROOF LEVEL
GA
MAN HOLE
MAT-A
RAMP UP
NEW LOCATION FOR SLUICE
SLUICE RM.
EQUIPMENT STORE
UTILITY
PROPOSED OUT PATIENT
SISTER
PROPOSED NURSING STAFF MALE
NURSING STAFF FEMALE
PANTRY
STERILE SUPPLY
LOCKER
W/C
SENOR STAFF OFFICE
WAITING
ASSIT. SENIOR NURSING STAFF
CLEAN SUPPLY
STORE
SISTER
MEDICAL GASES STORE
PROPOSED WORK RM.
PREP RM.
PROPOSED OPERATING THEATRE #3
PROPOSED OPERATING THEATRE #2
NURSES STATION
OBSTERICS & GYNAECOLOGY UNIT
EATING AREA
DOCTOR'S LOUNGE
AUTOCLAVE
PROPOSED I.C.U. (REQUIRE A/C UNIT)
PERIPHERAL CORRIDOR
DIRTY RECEPTION
PROPOSED RECOVERY
EXIT. OPERATING THEATRE #1
SCRUB AREA (GENERAL)
SCRUB AREA
4. THEATRE BLDG.
TOTAL 4900 s.f.
RAMP DN.
OPEN BREEZE WAY CORRIDOR
SOCIAL WORKER
EXECUTIVE OFFICER
AUDITORS
WAIT/ ADMISSION
CASHIERS
MEDICAL RECORDS
UTILITY RM.
MALE WASH RM.
FEMALE WASH RM.
ACCOUNTANT
RECORDS LIBRARIAN
MEDICAL RECORDS
CLERK OFFICE
3. HOSPITAL ADMIN.
TOTAL 3670 s.f.

FOR TENDER
2013-05-10

ELECTRICAL LEGEND

- 110v SINGLE RECEPTACLE (Wp DENOTES WEATHERPROOF) (GFCI DENOTES GROUND FAULT CIRCUIT INTERRUPTER) (SP DENOTES GENERAL PURPOSE OUTLETS)
- 110v DUPLEX RECEPTACLE (Wp DENOTES WEATHERPROOF) (GFCI DENOTES GROUND FAULT CIRCUIT INTERRUPTER) (SP DENOTES GENERAL PURPOSE OUTLETS) (SP DENOTES OUTLET THROUGH HP FILTER) (T DENOTES HOSPITAL-GRADE TAMPERPROOF RECEPTACLES)
- 220v SINGLE RECEPTACLE (Wp DENOTES WEATHERPROOF) (GFCI DENOTES GROUND FAULT CIRCUIT INTERRUPTER) (SP DENOTES GENERAL PURPOSE OUTLETS)
- 220v DUPLEX RECEPTACLE (Wp DENOTES WEATHERPROOF) (GFCI DENOTES GROUND FAULT CIRCUIT INTERRUPTER) (SP DENOTES GENERAL PURPOSE OUTLETS)
- 110v DUPLEX RECEPTACLE IN FLOOR BOX
- COMPUTER DRAW BOX
- TELEPHONE BOX
- ELECTRICAL DRAW BOX
- ISOLATOR
- ELECTRICAL PANEL BOARD (Recessed)
- ELECTRICAL PANEL BOARD (Surface mounted)
- SINGLE POLE SWITCH (4'-6" AFFL) (2 DENOTES TWO WAY OPERATION)
- SINGLE POLE SWITCH (4'-6" AFFL)
- SWITCH WITH NEON INDICATOR (4'-6" AFFL)
- FAN SWITCH (4'-6" AFFL)
- AIR CONDITION SWITCH (4'-6" AFFL)
- DIMMER SWITCH (4'-6" AFFL)
- DENOTES LIGHTS ON THE SAME CIRCUIT BUT CONTROLLED BY DIFFERENT SWITCHES.
- HOME RUN TO PANEL/DISTRIBUTION (DENOTES PANEL AND CIRCUIT NUMBERS)
- ELECTRICAL CONDUIT/DUCT RUN.
- TELEPHONE CONDUIT/DUCT RUN.
- CABLE TRUNKING FOR DATA & POWER ACCESS
- TELEVISION
- TELEPHONE POINT IN 4x4 DRAW BOX WITH 2x4 REDUCING RING
- COMPUTER POINT IN 4x4 DRAW BOX WITH 2x4 REDUCING RING. B DENOTES BOX WITH BLANK PLATE. # DENOTES QUANTITY OF NETWORK POINTS, NO # DENOTES 1# NETWORK POINT
- TELEPHONE & COMPUTER POINT IN 4x4 DRAW BOX WITH 2x4 REDUCING RING. B DENOTES BOX WITH BLANK PLATE. # DENOTES QUANTITY OF COMPUTER/TELEPHONE POINTS, NO # DENOTES 1# COMPUTER & 1# TELEPHONE POINT.
- COMPUTER POINT IN FLOOR BOX
- CMH COMPUTER MANHOLE
- EMH ELECTRICAL MANHOLE
- SMOKE DETECTOR
- HEAT DETECTOR
- SECURITY MOTION DETECTOR
- FIRE ALARM HORN/STROBES
- BREAK GLASS STATION/PULL STATION
- 110v RECEPTACLE SUSPENDED FROM CEILING (HUBBELL KELLUM TWISTLOCK)
- ELECTRICAL CONTACTOR
- BELL SYSTEM DRAW BOX
- ELECTRICAL BELL
- HAND DRIER
- EMERGENCY LIGHTS
- COMBINATION EMERGENCY AND EXIT LIGHT
- EXIT LIGHT
- LOCKABLE EMERGENCY STOP BUTTON.
- AUDIO DRAW BOX
- EM FITTED WITH BODINE B50 EMERGENCY BALLAST
- CAMERA
- TRANSFORMER
- INTERCOM
- SWITCHED 110v SINGLE RECEPTACLE IN CEILING
- SWITCHED 110v DUPLEX RECEPTACLE IN CEILING
- SWITCHED 230V SINGLE RECEPTACLE IN CEILING
- SWITCHED 230V DUPLEX RECEPTACLE IN CEILING
- SPEAKER DRAW BOX
- WIRELESS LIGHTING MOTION DETECTOR
- VC VOICE CONTROL DRAW BOX
- THERMOSTAT
- SECURITY KEYPAD
- MAGNETIC DOOR LOCK
- JUNCTION BOX
- 4x4 WALL RECESSED DRAW BOX FOR NURSE CALL SINGLE PATIENT PULL STATION @ 50" AFFL
- NURSE CALL DUTY STATION @ 66" AFFL
- 12x12 WALL RECESSED DRAW BOX FOR NURSE CALL MASTER ANNUNCIATOR SYSTEM @ 66" AFFL
- 4x4 WALL RECESSED DRAW BOX FOR NURSE CALL EMERGENCY STATION WITH PULL CORD @ 30" AFFL
- NURSE CALL CORRIDOR CEILING MOUNTED DOME LIGHT

No.	REVISION	DATE
A	2. ISOLATOR FOR KITCHEN HOOD FAN SHOWN.	2013-05-10
	1. POWER FOR STAFF LOUNGE OMITTED.	

This Drawing Is To Be Read With All Relevant Architectural, Structural And MEP Drawings. Report All Discrepancies, Omissions Or Errors To The Engineer.
IF IN DOUBT-ASK

LEVERAGE CONSULTING ENGINEERS INC.
#1 Erin Terrace, Brittons Cross Road, St. Michael BB14002, Barbados, W.I.

LEVERAGE CONSULTING ENGINEERS INC. HAS COPYRIGHT OF THIS DOCUMENT ©.

architect
MOULTON MAYERS

job name
MILTON CATO MEMORIAL HOSPITAL

drawing title
GROUND FLOOR POWER LAYOUT

drawn David B.	des/chk R. Forster	
scale 1/8"=1'-0"	date JUN. '12	status TENDER
job no. 120701	dwg. no. E-2	rev. A